

Approval Number 2108502  
Test Report: J-00390610 & J-00390611



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

22<sup>nd</sup> July 2021

VIP Polymers Ltd  
15 Windover Road  
Huntingdon  
Cambridgeshire  
PE29 7EB

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.**

**5365**

'EW45, EW50, EW53, EW54, EW54W, EW55, EW60, EW65, EW70, EW75, EW80, EW81 & EW85.'

Black coloured, compression moulded EPDM rubber materials.  
Shore hardness between 45 & 85. Tested in-radius size 1.4mm.

For use with water up to 60°C.

**APPROVAL NUMBER: 2108502**  
**APPROVAL HOLDER: VIP POLYMERS LTD**

This is a re-approval of 1607507 which is valid between July 2016 and July 2021.

The Scheme reserves the right to review approval.  
Approval 2108502 is valid between August 2021 and August 2026

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

**Ian Hughes**  
**WRAS Approvals Manager**